



Republic of the Philippines
MURCIA WATER DISTRICT

Municipality of Murcia
Province of Negros Occidental

Email add: murcia_waterdistrict@yahoo.com

Tele/Fax No: (034) 458-8844

February 23, 2022

RFQ No. 2022-010

REQUEST FOR QUOTATION

"SUPPLY AND DELIVERY OF 8"Ø Y-STRAINER AND 8"Ø PRESSURE SUSTAINING AND REDUCING VALVE"

The Murcia Water District (MWD) hereinafter referred to as "the Purchaser", through its Bids and Awards Committee (BAC), invite interested parties to submit price quotation for the project, **"SUPPLY AND DELIVERY OF 8"Ø Y-STRAINER AND 8"Ø PRESSURE SUSTAINING AND REDUCING VALVE"** through Small Value Procurement (Sec. 53.9 of R.A. No. 9184) with Approved Budget for the Contract (ABC) of Four Hundred Sixty Thousand Pesos Only (**P460,000.00**).

All items listed under the purchaser's specifications must be complied on a pass-fail basis.

Failure to meet any one of the requirements will result to rejection. Likewise, it is understood that Purchaser's specifications are minimum requirements.

Procurement procedures will be conducted in accordance with the provisions of the Implementing Rules and Regulations (IRR) of Republic Act No. 9184 (Government Procurement Reform Act).

It is the intent of the Purchaser to evaluate the quotation for the item and award will be made to the quotation resulting in the overall lowest cost. Contract Award will be made to the lowest evaluated quotation meeting purchaser's technical specifications.

Your price must be quoted in Philippine Peso and must include the unit price and total price, inclusive of all taxes to be paid and other incidental cost to the delivery site if the contract is awarded.

All quotations may be typewritten or handwritten and may be placed in sealed envelope marked **"SUPPLY AND DELIVERY OF 8"Ø Y-STRAINER AND 8"Ø PRESSURE SUSTAINING AND REDUCING VALVE"** (RFQ No. 2022-010) and must be submitted on or before **February 28, 2022, 5:00 P.M.** at the MWD Office. It may also be sent thru

email on our official email address at murciawaterdistrict@gmail.com on the specified time stated above and address to the BAC Chairperson, Engr. Paul G. Oñas.

Quotations shall be valid for thirty (30) calendar days from the deadline of submission of the same.

The delivery period shall be within **5 days** from receipt of the Purchase Order (PO). The supplier should inform the purchaser at least two (2) days before the date of delivery. The Purchaser shall have the right or to return the items that will be declared defective. The delivery will be made only during working days from 8:00 Am to 5:00 PM.

DELIVERY SITE: Murcia Water District Office
KM. 18, Eco Tourism Highway, Brgy. Salvacion
Murcia, Negros Occidental

TERMS OF PAYMENT: Payment shall be made 60 days after delivery


WARRANTY OF THE PRODUCT: 1-year warranty

The prospective supplier shall submit the following:

- a) Duly accomplished Quotation Form (*Attachment A*); and
- b) Brochures of the items offered, if any.

The Murcia Water District reserves the right to accept or reject any quotation, and to annul the procurement process and reject all quotations at any time prior to Contract award, without thereby incurring any liability to the affected supplier or suppliers. MWD also reserves the right to waive any required formality in the proposals received, and select the proposal which it determines to be the most advantageous to the government.

Prepared by:


CHARMAINE V. FLORES
BAC Secretary

Noted by:


Engr. PAUL G. OÑAS
BAC Chairperson




Republic of the Philippines
MURCIA WATER DISTRICT
 Municipality of Murcia
 Province of Negros Occidental
 Email add: murciawaterdistrict@gmail.com
 Tel/Fax No. (034) 458-8844

REQUEST FOR QUOTATION

Name of Supplier:			Tel. Nº.:		
Address:			Delivery Period:		
TIN Nº.:			Term of Payment:		
Item	Description	Quantity	Unit	Unit Price	BID Price
1	8" Ø Y-STRAINER WORKING PRESSURE: CLASS 125/150 WORKING TEMPERATURE: 0-100 deg Celsius PART NAME MATERIAL Body Cast Iron Bonnet Cast Iron Gasket NBRF/EPDM Bolt Carbon Steel Screen Stainless Steel;	1	unit		
2	8"Ø Pressure Sustaining and Reducing Valve Pilot System Specifications Standard Materials: Pilots: Body:Stainless steel Elastomers: Synthetic Rubber Springs: Galvanized Steel or Stainless Steel Tubing & Fittings: Stainless Steel 316 or Copper and Brass Accessories: Stainless Steel 316, Brass and Synthetic Rubber Elastomers Technical Data Specifications; End Connections(Pressure Ratings): Flanged: ISO PN16, PN25 (ANSI Class 150, 300) Threaded: BSP or NPT Valve Patterns: "Y" pattern Standard Materials; Body & Actuator: Ductile Iron Internals: Stainless Steel, Bronze & Coated Steel Diaphragm: Synthetic Rubber Nylon fabric-reinforced Seals: Synthetice Rubber Coating: Fusion Bonded Epoxy, RAL 5005 (Blue) approved for drinking wateer or Electrostatic Polyester Powder ***** Nothing Follows *****	1	unit		

Note:	ABOVE ITEMS ARE SUBJECT TO 6% VAT	Grand Total	
--------------	-----------------------------------	--------------------	--

Canvassed by:


Lady Lee M. Alintana
Procurement Assistant

Price quoted by:

Signature over printed name

Date