Republic of the Philippines



## **MURCIA WATER DISTRICT**

Municipality of Murcia Province of Negros Occidental Email add: murciawaterdistrict@gmail.com Tel/Fax No. (034) 458-8844

## **REQUEST FOR QUOTATION**

P.R. No.: <u>EOM-2024-01-003</u> ABC: <u>225,500.00</u>				
Name of Supplier:				
Address:				
Please quote your bid price on the items / listed below, subject to the General Condition on the last page, stating the shortes time of delivery and submit your quotation duly signed by your representative in the returned envelope attached herewith.  CHARMAINE V. FLORES  BAC Secretariat	t			
lote: 1) All entries must be legible. 2) Service / Delivery Period within the number of days agreed upon between the supplier and the Procuring Entity.				
Warranty shall be for a period of from date of acceptance by the procuring entity.      Price validity shall be a period of at least calendar days.				
5) PhilGEPS Registration Certificate shall be attached upon submission of the Quotation, if applicable.				
6) Bidders shall submit Original Brochures showing certification of the product being offered (optional).				
7) Mode of Delivery: [ ] Pick-up (Schedule) [ / ] Freight on Board (FOB)				
8) Place of Delivery: MURCIA WATER DISTRICT ADMIN BUILDING				
9) Delivery Period: within 15 days upon issuance of NOA				
10) Terms of Payment: within 30 days upon delivery				
11) All items are subject to 6% VAT.				

Item No.	Unit	Item and Description	Quantity	<b>Unit Price</b>	Total Amount
1	unit	B"Ø PSRV (F/F)	1		
		B"Ø Pressure Sustaining & Reducing Valve (F/F)			
		Pilot System Specifications	1		
		Standard Materials:			
		Pilots:			
		Body:Stainless steel			
		Elastomers: Synthetic Rubber			
		Springs: Galvanized Steel or Stainless Steel			
		Tubing & Fittings:			
		Stainless Steel 316 or Copper and Brass			
		Accessories:			
		Stainless Steel 316, Brass and Synthetic Rubber			
		Elastomers			
		Technical Data Specifications;			
		End Connections(Pressure Ratings):			
		Flanged: ISO PN16, PN25 ( ANSI Class 150, 300)			
		Threaded: BSP or NPT			
		Valve Patterns: "Y" pattern			
		Standard Materials;			
		Body & Actuator: Ductile Iron			
		nternals: Stainless Steel, Bronze & Coated Steel			
		Diaphragm: Synthetic Rubber Nylon fabric-reinforced			
		Seals: Synthetice Rubber			

01

Page 1 of 2 FM-ADM-04 Printed Date &Time: 01/10/2024 11:45:58 AM

3-03-2022

Item No.	Unit	Item and Description	Quantity	Unit Price	Total Amount	
2	piece	Coating: Fusion Bonded Epoxy, RAL 5005 (Blue) approved for drinking wateer or Electrostatic Polyester Powder 3"Ø Gate Valve D.I. (F/F) Non-rising stem, Square nut gate valve, Ductile iron body, Ansi 150,	1	,		
	0007	Flange type, w/o accessories				
3	set	1"Ø AIR RELEASE VALVE Plastic Body, Threaded Type Maximum Working Pressure: 16 Bar Maximum Working Temperature: 60 C Discharge High Air flow rates up to 160 m 3 /h Size: 1" Ø	2			
4	piece	4"Ø Gate Valve (F/F) Non-rising stem, Square nut gate valve, Ductile iron body, Ansi 150, Flange type, w/o accessories	1			
5	piece	6"Ø Gate Valve (F/F) Non-rising stem, Square nut gate valve, Ductile iron body, Ansi 150, Flange type, w/o accessories ************************************	1			
	L			Grand Total		
Amount	in Words:					
After hav	ing carefu	ılly read and accepted your General Condition. I / We	quote you on	the item at pric	es noted above.	
				Printed Name / Signature		
	Tel. No. / Fax No.					
				TIN No.		
Canvasse	er/Procure	ement Unit: Lady Lee M. Alintana		Date	9	